

ADDENDUM NO. 1 – 2023:11
CITY OF JONESBORO
RESTROOM AND CONCESSION STAND FOR JOE MACK CAMPBELL PARK
APRIL 13, 2023

TO: Proposal Holders – 2023:11
SUBJECT: Plan Clarification

Item 1: Sheet C100

Existing parking lot adjacent to building site may be used as a layout area during construction, within reason. Contractor shall keep the area neat and clean during use, and restore the area to pre-use condition at the end of use.

Item 2: Sheet A401

A smooth-face CMU shall replace the precast water tables called out on the wall section details on Sheet A401. Exact color of CMU to be selected by Owner from samples provided by Contractor prior to install.

Item 3: Sheet E103

Electrical Service – 2-inch secondary conduit to extend roughly 80-feet northeast of proposed building pad to a new power pole and pole-mounted transformer to be provided and installed by CWL. The primary conduit and pad mounted transformer call out on Sheet E103 is to be deleted from bid.

LIST ADDENDUM NO. 1 ON THE ACKNOWLEDGEMENT FORM IN THE FRONT OF YOUR PROPOSAL. ACKNOWLEDGE RECEIPT OF THIS ADDENDUM BY SIGNING AND DATING THE FORM. ATTACH THIS ADDENDUM LETTER INSIDE THE FRONT COVER OF YOUR PROPOSAL. ACKNOWLEDGEMENT MUST BE MADE AND THE FORM RETURNED WITH THE PROPOSAL.

Sincerely,



Craig Light
City Engineer

Attachment